

The second second

OFFICE, PRINCIPAL GOVERNMENT TULSI COLLEGE, ANUPPUR

Affiliated to Awadhesh Pratap Singh University Rewa (MP)

Registered Under Section 2 (F) & 12 (B) of UGC Act

E-mail: hegtdcano@mp.gov.in

29893076404

F	ire Audit Report Year-2023	
Sir, Sub:- Submission GOVT.TULSI DEG [SHAHDOL]	of fire audit report of bui REE COLLEGE ANUPPUR	
building/premises on? Equipments/installation		Fire Audit of the said
[APPROX]NO. OF FLOORS FLOOR+FIRST FLOOR		
2. Details of fire system in S.no. Particular		-
	Available/Installed or not installed (as per requirements) (give comments)	Comments for working of system (attach details, if needed)
1- Access	YES AVAILABLE	liceded)
2- WET RISER	NOT REQUIRED AS PER NBC	
		OPINCIPAL Anuppur
	G01	PRINCIPAL Anuppur Tulsi College (M.P.) Dist. Anuppur (M.P.)




OFFICE, PRINCIPAL GOVERNMENT TULSI COLLEGE, ANUPPUR

Affiliated to Awadhesh Pratap Singh University Rewa (MP)

Registered Under Section 2 (F) & 12 (B) of UGC Act

E-mail: hegtdcano@mp.gov.in



3-	Down Comer	2016	
	Down Comer	NOT REQUIRED AS PER NBC	
4-	Hose Reel	2016	
		NOT REQUIRED AS PER NBC	
5-	Automatic Sprinkler system	NOT REQUIRED AS PER NBC 2016	
5-	Yard Hydtant	NOT REQUIRED AS PER NBC 2016	
7-	Underground Tank with Draw off Connection	NOT REQUIRED AS PER NBC 2016	
3.	Terrace Tank	YES AVAILABLE TOTAL CAPACITY= 4000LTR	
)-	Fire Pump	NOT AVAILABLE	

10-	Terrace Pump	NOT AVAILABLE	
11-	First Aid Fire	YES AVAILABLE	
	Fighting Appliances	ABC TYPE 4KG/6KG FIRE	
		EXTINGUISHER =07 NOS	
12-	Pressurization System	NOT AVAILABLE	
13-	Auto Detection System	NOT AVAILABLE	NOT REQUIRED AS PER NBC 2016
14-	Manual operated Electrical Fire Alarm System	NOT AVAILABLE	NOT REQUIRED AS PER NBC 2016
15-	P.A System with talk back facility	NOT AVAILABLE	
16-	Emergency Light	NOT AVAILABLE	
17-	Auto D.G. Set	NOT AVAILABLE	
8-	Illuminated Exit Sign	NOT AVAILABLE	REQUIRED AS PER NBC 2016
9-	Means of Escape	YES AVAILABLE	
0-	Compartmantation	NOT AVAILABLE	
1-	MCB/ELCB	YES AVAILABLE	
2-	Fireman Switch in Lift	NOT AVAILABLE	
3-	Hose Boxes with Delivery Hose and Branch	NOT AVAILABLE	PRINCIPAL Anuppur ONT. Tulsi College (M.P.)
4-	Refuge Area	YES AVAILABLE [OUTSIDE PREMISES]	OVI. TUISI COMO (NV.



OFFICE, PRINCIPAL GOVERNMENT TULSI COLLEGE, ANUPPUR

Affiliated to Awadhesh Pratap Singh University Rewa (MP)

Registered Under Section 2 (F) & 12 (B) of UGC Act

E-mail: hegtdcano@mp.gov.in

29893076404

25-Any other installation

NOT AVAILABLE

CO2 TYPE EXTINGUISHER I REQUIRED

It is certified that the Installed Fire system as given are in workingcondition and safe.

Conclusion

- 1. HOSE REEL NOT REQUIRED AS PER NBC 2016
- 2. WET RISER NOT REQUIRED AS PER NBC 2016
- 3. YARD HYDRANT NOT REQUIRED AS PER NBC 2016
- 4. UNDERGROUND TANK NOT REQUIRED AS PER NBC 2016
- 5. AS PER NBC 2016 SEPARATED WATER TANK WITH CAPACITY 10000 LTR IS REQUIRED
- 6.AUTOMATIC SPRINKLER SYSTEM IS NOT REQUIRED AS PER NBC 2016
- 7 FIRE PUMP NOT REQUIRED AS PER NBC 2016
- 8 TERRACE PUMP MUST HAVE CONNECTED TO GENERATOR BY CHANGE OVER
- 9. AS PER NBC 2016 MINIMUM TOTAL 10 NO ABC TYPE 4KG/6KG FIRE EXTINGUISHER AND 4.5 KG CO2 TYPE FIRE EXTINGUISHER 5 NO ARE REQUIRES
- 10.AS PER NBC 2016 EXIT SIGNS ARE REQUIRED
- 11.MCP & HOOTER NOT REQUIRED AS PER NBC 2016
- 12 AUTO DETECTION SYSTEM NOT REQUIRED AS PER NBC 2016

Date:

29/06/2023

Govi. Tulsi College Angres

Name of Fire Engine

Jiest Wonbbar (W. 2.)